

# DESIGN CERTIFICATE

## DESCRIPTION:

This certificate relates to the adequacy of the existing roof at the described location to support the pv-panels and to their fixings.

## LOCATION:

Wardli Youth Center, 13 McKenna road, Christie Downs SA

## DETAILS:

### Roof:

The adequacy of the existing roof structures to carry the loads arising from the pv-installations have been assessed based on comparing the loads for which the purlins would have been designed with the loads arising from the installation of the pv-panels and have been found to be satisfactory.

### Fixings:

The landscape format Longi Solar 370W panels are to be mounted on pairs of Clenergy Eco rails and secured to the purlins using Clenergy tin feet and Buildex 14-11 hex head zips.

## REFERENCES:


Westside Energy General arrangement

LSEC calculations Job No 21042-3 Rev 0

## STANDARDS:

AS1170.0 Structural design actions - General principles  
AS1170.1 Structural design actions - Dead and imposed loads  
AS1170.2 Structural design actions - Wind loads

It is certified that the described item(s) have been designed and assessed using the listed Standards, conventional engineering principles and good practice for the location and function detailed above. No physical testing of items has been undertaken.



SCJ Lovell BSc, CEng, MStructE, NER(Structural), RPEQ 13036

Date: 24 March 2021



ABN: 33 473 233 682


PO Box 334  
Macclesfield  
South Australia 5153

[www.lsec.com.au](http://www.lsec.com.au)

m. 0420 859 809







# Lovell Structural Engineering Consultancy

PO Box 334, Macclesfield, SA 5153

w: LSEC.com.au

t: 0420 859 809

ABN: 33 473 233 682

## STRUCTURAL CALCULATIONS

**Project:** pv-Panel installation

**Address:** Wardli Youth Center, 13 McKinna Rd, Christie Downs

**Client:** Westside Energy

**Project #:** 21042-3

| Revision | Date     | Description    |
|----------|----------|----------------|
| 0        | 24/03/21 | Issued for use |
|          |          |                |
|          |          |                |

**Intellectual Property, Copyright and Limitations:** The structural engineering concepts, methodologies and design philosophies described or otherwise utilised in this document are the intellectual property of Lovell Structural Engineering Consultancy (LSEC). Without the written permission of LSEC, the physical or electronic distribution of this document, either in part or in whole, for purposes other than those for completing the Project constitutes an infringement of copyright. This document has been prepared for sole use of the Client in connection with the Project and LSEC accepts no liability or responsibility in respect of any use of or reliance upon this document by any third party.


## INTRODUCTION

The following structural calculations form part of the certification justifying the fixings for the pv-installation to the roof structure and the roof structure itself at the project location to withstand the applied loads and are to be read in conjunction with the certificate and with the reference drawings.

The calculation have been prepared by SCJ Lovell BSc CEng MStructE NER RPEQ

## DESCRIPTION AND DESIGN PHILOSOPHY

Overall, the building measures around 23.6 m by 36.5 m on plan with an average roof height of around 3.5 m.



Site information provided by Westside gives the 5-degree duo-pitch roof to comprise pierce corrugated sheeting and the image suggest purlins at 1200 mm spacing.

The installation comprises flush mounted pv-panels installed in landscape format on Clenergy Eco rails and fixed to the purlins using proprietary Clenergy tin feet and Buildex 14-11 hex head zips.

It is a pv-panel manufacturer's requirement that the panels are not trafficked by maintenance personnel nor that any materials are stacked on the panels; if it is necessary to undertake any maintenance work then this is conducted by removing panels to create the required access.

The panels are in small isolated groups and for the purposes of design of the fixings the wind load coefficient on the panels will be taken as 1.7. The wind load on the panel comprises the suction on the upper surface and the pressure on the lower surface however the pressure also acts on the roof sheet hence the nett effect on the roof is that due to the suction on the upper surface less the weight of the panel. For flush mounted panels the wind action on the upper surface is equivalent to that on the original roof surface hence there is no additional wind uplift on the roof.

The adequacy of the roof will be proven by comparing the loads for which the purlins would have been designed with the loads for which they will be subjected.

The assessment will be in accordance with:

|          |  |
|----------|--|
| AS1170.0 | Structural design actions - General principles       |
| AS1170.1 | Structural design actions - Dead and imposed actions |
| AS1170.2 | Structural design actions - Wind actions             |

## REFERENCE DOCUMENTS

Westside - Wardli Youth Center, General Arrangement

Clenergy installation manual

Longi Solar 370W panel data sheet

## PANEL SYSTEM

|                  |        |                          |
|------------------|--------|--------------------------|
| Panel dimensions | Length | $p_l := 1755 \text{ mm}$ |
|                  | Width  | $p_w := 1038 \text{ mm}$ |

## Loading from pv-system

|                        |  |
|------------------------|--|
| Weight of panel        | $G_{panel} := 19.5 \text{ kg} \cdot g = 191 \text{ N}$                     |
| Weight of frame        | $G_{frame} := 3 \text{ kg} \cdot g = 29 \text{ N}$                         |
| Dead load of pv-system | $g_{pv} := \frac{(G_{panel} + G_{frame})}{p_l \cdot p_w} = 121 \text{ Pa}$ |

## LOADINGS

### Dead loads

|                              |   |
|------------------------------|---|
| Roof sheeting                | $g_1 := 4.7 \text{ kg} \cdot m^{-2}$                      |
| Purlins                      | $g_2 := 4.5 \text{ kg} \cdot m^{-2}$                      |
| Ceiling and services - allow | $g_3 := 12 \text{ kg} \cdot m^{-2}$                       |
| Roof dead load               | $g_{kr} := (g_1 + g_2 + g_3) \cdot g = 0.208 \text{ kPa}$ |

**Imposed load**

General load

$$q_{kr} := 0.25 \text{ kPa}$$

**Wind loads**

A wind analysis has been undertaken using CheckWind software

**CHECKWIND v5.3.2 AS/NZS 1170 SITE REPORT**

**rev0**

|              |          |               |            |                     |           |
|--------------|----------|---------------|------------|---------------------|-----------|
| STRUCTURE:   | BUILDING | LATITUDE:     | -35.136098 | CRITICAL DIRECTION: | West      |
| ORIENTATION: | 0°       | LONGITUDE:    | 138.488468 | Md:                 | 1.00      |
| WIDTH:       | 23.60 m  | ELEVATION:    | 45.00 m    | TC:                 | 3.00      |
| LENGTH:      | 36.50 m  |               |            | Mz, cat:            | 0.8300    |
| HEIGHT (h):  | 4.00 m   | WIND REGION:  | A1         | Ms:                 | 1.0       |
| BASE RL:     | 0.00 m   | ULTIMATE ARI: | 500 YEARS  | Mh:                 | 1.0       |
|              |          | ULTIMATE VR:  | 45 m/s     | Mlee:               | 1.0       |
|              |          |               |            | Me1:                | 1.0       |
|              |          |               |            | Mt:                 | 1.0       |
|              |          |               |            | Vdes, θ:            | 37.35 m/s |
|              |          |               |            | qdes, θ:            | 0.84 kPa  |

$$q_{sit} := 0.84 \text{ kPa}$$



### Existing purlins

Pitch of roof  $\phi := 5 \text{ deg}$

Purlin spacing  $s_p := 1.20 \text{ m}$

### Additional dead loads from pv-panels

Original design load on purlins  $E_{d.ex} := \left( \frac{1.2 \cdot g_{kr}}{\cos(\alpha)} + q_{kr} \right) \cdot s_p = 0.599 \text{ kN} \cdot \text{m}^{-1}$

General load case  $E_{d.1} := \frac{1.35 \cdot (g_{kr} + g_{pv})}{\cos(\alpha)} \cdot s_p = 0.533 \text{ kN} \cdot \text{m}^{-1}$

**CHECK**  $\frac{E_{d.1}}{E_{d.ex}} = 0.889 < 1 \text{ :: OK}$

**Existing purlins OK for additional dead loads from pv panels**

### Fixings

For Buildex 14-11 hex head zips in 1.2 mm thick G450 purlins

Pull out capacity  $N_{fix.a} := -3.87 \text{ kN}$

Capacity reduction factor  $\phi := 0.7$

Aerodynamic shape factor  $C_{fig} := -1.7$

Design wind pressure  $p := q_{sit} \cdot C_{fig} = -1428 \text{ Pa}$

Load on panels  $W := p + g_{pv} = -1307 \text{ Pa}$

For panels supported by 2 rails,  
load per fixing  $F_{fix} := W \cdot \frac{p_l}{2} \cdot s_p = -1.376 \text{ kN}$

**CHECK**  $\frac{F_{fix}}{\phi \cdot N_{fix.a}} = 0.508 < 1 \text{ :: OK}$

**USE 2 RAILS PER PANEL AND BUILDEX 14-11 HEX HEAD ZIPS**

----- STRUCTURE DATA -----

TYPE: BUILDING  
ORIENTATION: 0.0°  
ROOF: GABLE  
WIDTH: 23.60 m  
LENGTH: 36.50 m  
ROOF SLOPE (α): 5.0°  
HEIGHT (h): 4.00 m  
BASE RL: 0.00 m

----- SITE DATA -----

LOCATION

LATITUDE: -35.136098  
LONGITUDE: 138.488468  
ELEVATION: 45.00 m

DESIGN

REFERENCE: AS/NZS 1170  
IMPORTANCE LEVEL: 2  
LIFE: 50 YEARS

WIND

REGION: A1  
ULTIMATE ARI: 500 YEARS

REGIONAL WIND SPEED (VR)

- Calculated as per AS/NZS 1170.2 Section 3.2.

ULTIMATE: 45 m/s  
ICE: 34 m/s  
SERVICEABILITY: 37 m/s

DIRECTION MULTIPLIER (Md)

- Calculated for Region A1 as per AS/NZS 1170.2 Section 3.3.

WIND Md

N 0.90  
NE 0.80  
E 0.80  
SE 0.80  
S 0.85  
SW 0.95  
W 1.00  
NW 0.95

TERRAIN/HEIGHT MULTIPLIER (Mz,cat)

- Calculated using averaging as per AS/NZS 1170.2 Section 4.2.3 and varies with height.

NORTH WIND: Mz,cat = 0.8300 (TC 3.00)

ZONE 1: TC 3 to 580.00 m

NORTH EAST WIND: Mz,cat = 0.8300 (TC 3.00)

ZONE 1: TC 3 to 580.00 m

EAST WIND: Mz,cat = 0.8393 (TC 2.88)

ZONE 1: TC 3 to 464.00 m

ZONE 2: TC 2.5 to 580.00 m

SOUTH EAST WIND: Mz,cat = 0.8300 (TC 3.00)

ZONE 1: TC 3 to 580.00 m

SOUTH WIND: Mz,cat = 0.8300 (TC 3.00)

ZONE 1: TC 3 to 580.00 m

SOUTH WEST WIND: Mz,cat = 0.8300 (TC 3.00)

ZONE 1: TC 3 to 580.00 m

WEST WIND: Mz,cat = 0.8300 (TC 3.00)

ZONE 1: TC 3 to 580.00 m

NORTH WEST WIND: Mz,cat = 0.8300 (TC 3.00)

ZONE 1: TC 3 to 580.00 m

SHIELDING MULTIPLIER (Ms)

- Calculated as per AS/NZS 1170.2 Section 4.3 and varies with height.

NORTH WIND: Ms = 1.0

| ID  | HEIGHT | ELEVATION | SLOPE  | AREA               | BREADTH | LATITUDE   | LONGITUDE  |
|-----|--------|-----------|--------|--------------------|---------|------------|------------|
| 015 | 3.00 m | 45.00 m   | 0.0000 | 103 m <sup>2</sup> | 8.56 m  | -35.135792 | 138.488365 |

NORTH EAST WIND: Ms = 1.0

| ID  | HEIGHT | ELEVATION | SLOPE  | AREA               | BREADTH | LATITUDE   | LONGITUDE  |
|-----|--------|-----------|--------|--------------------|---------|------------|------------|
| 005 | 3.00 m | 46.00 m   | 0.0166 | 210 m <sup>2</sup> | 9.37 m  | -35.135930 | 138.489099 |

EAST WIND: Ms = 1.0



| ID  | HEIGHT | ELEVATION | SLOPE  | AREA               | BREADTH | LATITUDE   | LONGITUDE  |
|-----|--------|-----------|--------|--------------------|---------|------------|------------|
| 002 | 3.00 m | 46.00 m   | 0.0130 | 339 m <sup>2</sup> | 20.87 m | -35.135944 | 138.489290 |
| 005 | 3.00 m | 46.00 m   | 0.0166 | 210 m <sup>2</sup> | 16.78 m | -35.135930 | 138.489099 |
| 011 | 3.00 m | 45.50 m   | 0.0076 | 125 m <sup>2</sup> | 1.71 m  | -35.136372 | 138.489108 |
| 012 | 3.00 m | 46.00 m   | 0.0127 | 123 m <sup>2</sup> | 9.46 m  | -35.136127 | 138.489332 |
| 013 | 3.00 m | 45.50 m   | 0.0087 | 114 m <sup>2</sup> | 14.92 m | -35.136161 | 138.489095 |

SOUTH EAST WIND: Ms = 1.0

| ID  | HEIGHT | ELEVATION | SLOPE  | AREA               | BREADTH | LATITUDE   | LONGITUDE  |
|-----|--------|-----------|--------|--------------------|---------|------------|------------|
| 004 | 3.00 m | 46.00 m   | 0.0127 | 213 m <sup>2</sup> | 16.71 m | -35.136512 | 138.489167 |
| 011 | 3.00 m | 45.50 m   | 0.0076 | 125 m <sup>2</sup> | 14.99 m | -35.136372 | 138.489108 |

SOUTH WIND: Ms = 1.0

| ID  | HEIGHT | ELEVATION | SLOPE  | AREA               | BREADTH | LATITUDE   | LONGITUDE  |
|-----|--------|-----------|--------|--------------------|---------|------------|------------|
| 001 | 3.00 m | 45.00 m   | 0.0000 | 363 m <sup>2</sup> | 12.65 m | -35.136604 | 138.488440 |

SOUTH WEST WIND: Ms = 1.0

| ID  | HEIGHT | ELEVATION | SLOPE  | AREA               | BREADTH | LATITUDE   | LONGITUDE  |
|-----|--------|-----------|--------|--------------------|---------|------------|------------|
| 006 | 3.00 m | 44.00 m   | 0.0156 | 192 m <sup>2</sup> | 17.32 m | -35.136392 | 138.487863 |
| 007 | 3.00 m | 43.50 m   | 0.0202 | 185 m <sup>2</sup> | 13.65 m | -35.136392 | 138.487735 |
| 008 | 3.00 m | 44.50 m   | 0.0094 | 175 m <sup>2</sup> | 17.32 m | -35.136485 | 138.488121 |
| 009 | 3.00 m | 44.00 m   | 0.0181 | 172 m <sup>2</sup> | 17.30 m | -35.136424 | 138.488011 |

WEST WIND: Ms = 1.0

| ID  | HEIGHT | ELEVATION | SLOPE  | AREA               | BREADTH | LATITUDE   | LONGITUDE  |
|-----|--------|-----------|--------|--------------------|---------|------------|------------|
| 006 | 3.00 m | 44.00 m   | 0.0156 | 192 m <sup>2</sup> | 1.70 m  | -35.136392 | 138.487863 |
| 007 | 3.00 m | 43.50 m   | 0.0202 | 185 m <sup>2</sup> | 8.09 m  | -35.136392 | 138.487735 |
| 010 | 3.00 m | 43.50 m   | 0.0189 | 125 m <sup>2</sup> | 14.27 m | -35.135912 | 138.487624 |
| 014 | 3.00 m | 43.50 m   | 0.0236 | 107 m <sup>2</sup> | 7.81 m  | -35.135884 | 138.487821 |

NORTH WEST WIND: Ms = 1.0

| ID  | HEIGHT | ELEVATION | SLOPE  | AREA               | BREADTH | LATITUDE   | LONGITUDE  |
|-----|--------|-----------|--------|--------------------|---------|------------|------------|
| 003 | 3.00 m | 44.50 m   | 0.0072 | 271 m <sup>2</sup> | 27.49 m | -35.135614 | 138.487985 |
| 014 | 3.00 m | 43.50 m   | 0.0236 | 107 m <sup>2</sup> | 9.79 m  | -35.135884 | 138.487821 |
| 015 | 3.00 m | 44.00 m   | 0.0000 | 103 m <sup>2</sup> | 5.42 m  | -35.135792 | 138.488365 |
| 016 | 3.00 m | 44.00 m   | 0.0197 | 91 m <sup>2</sup>  | 13.47 m | -35.135843 | 138.488006 |

TOPOGRAPHIC MULTIPLIER (Mt)

- Calculated as per AS/NZS 1170.2 Section 4.4 and varies with height.
- Water Surface has been defined @ RL 0.00 m.

| WIND | CRITICAL | TOPOGRAPHY | H       | Lu       | x          | Mh  | Mt  |
|------|----------|------------|---------|----------|------------|-----|-----|
| N    | NNW      | Escarpment | 37.00 m | 370.00 m | 840.00 m   | 1.0 | 1.0 |
| NE   | NE       | Escarpment | 14.50 m | 91.67 m  | -2380.00 m | 1.0 | 1.0 |
| E    | ENE      | Flat       | 24.50 m | 285.00 m | 1940.00 m  | 1.0 | 1.0 |
| SE   | SSE      | Escarpment | 26.00 m | 184.29 m | -1680.00 m | 1.0 | 1.0 |
| S    | SSE      | Escarpment | 26.00 m | 184.29 m | -1680.00 m | 1.0 | 1.0 |
| SW   | SSW      | Escarpment | 37.00 m | 328.57 m | -2160.00 m | 1.0 | 1.0 |
| W    | WSW      | Flat       | 12.00 m | 260.00 m | -500.00 m  | 1.0 | 1.0 |
| NW   | NNW      | Escarpment | 37.00 m | 370.00 m | 840.00 m   | 1.0 | 1.0 |

----- ANALYSIS -----

LOAD CASE 01: Ultimate Wind

NORTH WIND

| RL     | Md   | Mz,cat | ns | hs     | bs     | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|--------|--------|-----|-----------|------------|
| 4.00 m | 0.90 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 33.62 m/s | 0.6782 kPa |
| 3.60 m | 0.90 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 33.62 m/s | 0.6782 kPa |
| 3.20 m | 0.90 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 33.62 m/s | 0.6782 kPa |
| 2.80 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 33.52 m/s | 0.6742 kPa |
| 2.40 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 33.52 m/s | 0.6742 kPa |
| 2.00 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 33.52 m/s | 0.6742 kPa |
| 1.60 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 33.52 m/s | 0.6742 kPa |
| 1.20 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 33.52 m/s | 0.6742 kPa |
| 0.80 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 33.52 m/s | 0.6742 kPa |
| 0.40 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 33.52 m/s | 0.6742 kPa |
| 0.00 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 33.52 m/s | 0.6742 kPa |

NORTH EAST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs     | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|--------|--------|-----|-----------|------------|
| 4.00 m | 0.80 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 30.00 m/s | 0.5400 kPa |
| 3.60 m | 0.80 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 30.00 m/s | 0.5400 kPa |
| 3.20 m | 0.80 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.80 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.40 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.00 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 1.60 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 1.20 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.80 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.40 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.00 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 30.00 m/s | 0.5400 kPa |

EAST WIND

| RL     | Md   | Mz,cat | ns | hs | bs | Ms  | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|----|----|-----|-----|-----------|------------|
| 4.00 m | 0.80 | 0.8393 | 0  | -  | -  | 1.0 | 1.0 | 30.21 m/s | 0.5476 kPa |
| 3.60 m | 0.80 | 0.8391 | 0  | -  | -  | 1.0 | 1.0 | 30.21 m/s | 0.5476 kPa |

|        |      |        |   |        |         |        |     |           |            |
|--------|------|--------|---|--------|---------|--------|-----|-----------|------------|
| 3.20 m | 0.80 | 0.8390 | 0 | -      | -       | 1.0    | 1.0 | 30.20 m/s | 0.5472 kPa |
| 2.80 m | 0.80 | 0.8389 | 5 | 3.00 m | 12.75 m | 0.8509 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.40 m | 0.80 | 0.8387 | 5 | 3.00 m | 12.75 m | 0.8509 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.00 m | 0.80 | 0.8386 | 5 | 3.00 m | 12.75 m | 0.8509 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 1.60 m | 0.80 | 0.8385 | 5 | 3.00 m | 12.75 m | 0.8509 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 1.20 m | 0.80 | 0.8383 | 5 | 3.00 m | 12.75 m | 0.8509 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.80 m | 0.80 | 0.8382 | 5 | 3.00 m | 12.75 m | 0.8509 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.40 m | 0.80 | 0.8381 | 5 | 3.00 m | 12.75 m | 0.8509 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.00 m | 0.80 | 0.8380 | 5 | 3.00 m | 12.75 m | 0.8509 | 1.0 | 30.00 m/s | 0.5400 kPa |

SOUTH EAST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs      | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|---------|--------|-----|-----------|------------|
| 4.00 m | 0.80 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 30.00 m/s | 0.5400 kPa |
| 3.60 m | 0.80 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 30.00 m/s | 0.5400 kPa |
| 3.20 m | 0.80 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.80 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.40 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.00 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 1.60 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 1.20 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.80 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.40 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.00 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 30.00 m/s | 0.5400 kPa |

SOUTH WIND

| RL     | Md   | Mz,cat | ns | hs     | bs      | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|---------|--------|-----|-----------|------------|
| 4.00 m | 0.85 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 31.75 m/s | 0.6048 kPa |
| 3.60 m | 0.85 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 31.75 m/s | 0.6048 kPa |
| 3.20 m | 0.85 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 31.75 m/s | 0.6048 kPa |
| 2.80 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 30.55 m/s | 0.5600 kPa |
| 2.40 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 30.55 m/s | 0.5600 kPa |
| 2.00 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 30.55 m/s | 0.5600 kPa |
| 1.60 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 30.55 m/s | 0.5600 kPa |
| 1.20 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 30.55 m/s | 0.5600 kPa |
| 0.80 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 30.55 m/s | 0.5600 kPa |
| 0.40 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 30.55 m/s | 0.5600 kPa |
| 0.00 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 30.55 m/s | 0.5600 kPa |

SOUTH WEST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs      | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|---------|--------|-----|-----------|------------|
| 4.00 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 35.48 m/s | 0.7553 kPa |
| 3.60 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 35.48 m/s | 0.7553 kPa |
| 3.20 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 35.48 m/s | 0.7553 kPa |
| 2.80 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.40 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 2.00 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 1.60 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 1.20 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.80 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.40 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 30.00 m/s | 0.5400 kPa |
| 0.00 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 30.00 m/s | 0.5400 kPa |

WEST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs     | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|--------|--------|-----|-----------|------------|
| 4.00 m | 1.00 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 37.35 m/s | 0.8370 kPa |
| 3.60 m | 1.00 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 37.35 m/s | 0.8370 kPa |
| 3.20 m | 1.00 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 37.35 m/s | 0.8370 kPa |
| 2.80 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 33.70 m/s | 0.6814 kPa |
| 2.40 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 33.70 m/s | 0.6814 kPa |
| 2.00 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 33.70 m/s | 0.6814 kPa |
| 1.60 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 33.70 m/s | 0.6814 kPa |
| 1.20 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 33.70 m/s | 0.6814 kPa |
| 0.80 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 33.70 m/s | 0.6814 kPa |
| 0.40 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 33.70 m/s | 0.6814 kPa |
| 0.00 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 33.70 m/s | 0.6814 kPa |

NORTH WEST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs      | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|---------|--------|-----|-----------|------------|
| 4.00 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 35.48 m/s | 0.7553 kPa |
| 3.60 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 35.48 m/s | 0.7553 kPa |
| 3.20 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 35.48 m/s | 0.7553 kPa |
| 2.80 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 30.31 m/s | 0.5512 kPa |
| 2.40 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 30.31 m/s | 0.5512 kPa |
| 2.00 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 30.31 m/s | 0.5512 kPa |
| 1.60 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 30.31 m/s | 0.5512 kPa |
| 1.20 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 30.31 m/s | 0.5512 kPa |
| 0.80 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 30.31 m/s | 0.5512 kPa |
| 0.40 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 30.31 m/s | 0.5512 kPa |
| 0.00 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 30.31 m/s | 0.5512 kPa |

LOAD CASE 02: Serviceability Wind

NORTH WIND

| RL     | Md   | Mz,cat | ns | hs     | bs     | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|--------|--------|-----|-----------|------------|
| 4.00 m | 0.90 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 27.64 m/s | 0.4584 kPa |
| 3.60 m | 0.90 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 27.64 m/s | 0.4584 kPa |
| 3.20 m | 0.90 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 27.64 m/s | 0.4584 kPa |
| 2.80 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 27.56 m/s | 0.4557 kPa |
| 2.40 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 27.56 m/s | 0.4557 kPa |
| 2.00 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 27.56 m/s | 0.4557 kPa |
| 1.60 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 27.56 m/s | 0.4557 kPa |
| 1.20 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 27.56 m/s | 0.4557 kPa |
| 0.80 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 27.56 m/s | 0.4557 kPa |
| 0.40 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 27.56 m/s | 0.4557 kPa |
| 0.00 m | 0.90 | 0.8300 | 1  | 3.00 m | 8.56 m | 0.9973 | 1.0 | 27.56 m/s | 0.4557 kPa |

NORTH EAST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs     | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|--------|--------|-----|-----------|------------|
| 4.00 m | 0.80 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 24.57 m/s | 0.3622 kPa |
| 3.60 m | 0.80 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 24.57 m/s | 0.3622 kPa |
| 3.20 m | 0.80 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 24.57 m/s | 0.3622 kPa |
| 2.80 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 24.29 m/s | 0.3540 kPa |
| 2.40 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 24.29 m/s | 0.3540 kPa |
| 2.00 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 24.29 m/s | 0.3540 kPa |
| 1.60 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 24.29 m/s | 0.3540 kPa |
| 1.20 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 24.29 m/s | 0.3540 kPa |
| 0.80 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 24.29 m/s | 0.3540 kPa |
| 0.40 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 24.29 m/s | 0.3540 kPa |
| 0.00 m | 0.80 | 0.8300 | 1  | 3.00 m | 9.37 m | 0.9886 | 1.0 | 24.29 m/s | 0.3540 kPa |

EAST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs      | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|---------|--------|-----|-----------|------------|
| 4.00 m | 0.80 | 0.8393 | 0  | -      | -       | 1.0    | 1.0 | 24.84 m/s | 0.3702 kPa |
| 3.60 m | 0.80 | 0.8391 | 0  | -      | -       | 1.0    | 1.0 | 24.84 m/s | 0.3702 kPa |
| 3.20 m | 0.80 | 0.8390 | 0  | -      | -       | 1.0    | 1.0 | 24.83 m/s | 0.3699 kPa |
| 2.80 m | 0.80 | 0.8389 | 5  | 3.00 m | 12.75 m | 0.8509 | 1.0 | 21.13 m/s | 0.2679 kPa |
| 2.40 m | 0.80 | 0.8387 | 5  | 3.00 m | 12.75 m | 0.8509 | 1.0 | 21.12 m/s | 0.2676 kPa |
| 2.00 m | 0.80 | 0.8386 | 5  | 3.00 m | 12.75 m | 0.8509 | 1.0 | 21.12 m/s | 0.2676 kPa |
| 1.60 m | 0.80 | 0.8385 | 5  | 3.00 m | 12.75 m | 0.8509 | 1.0 | 21.12 m/s | 0.2676 kPa |
| 1.20 m | 0.80 | 0.8383 | 5  | 3.00 m | 12.75 m | 0.8509 | 1.0 | 21.11 m/s | 0.2674 kPa |
| 0.80 m | 0.80 | 0.8382 | 5  | 3.00 m | 12.75 m | 0.8509 | 1.0 | 21.11 m/s | 0.2674 kPa |
| 0.40 m | 0.80 | 0.8381 | 5  | 3.00 m | 12.75 m | 0.8509 | 1.0 | 21.11 m/s | 0.2674 kPa |
| 0.00 m | 0.80 | 0.8380 | 5  | 3.00 m | 12.75 m | 0.8509 | 1.0 | 21.11 m/s | 0.2674 kPa |

SOUTH EAST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs      | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|---------|--------|-----|-----------|------------|
| 4.00 m | 0.80 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 24.57 m/s | 0.3622 kPa |
| 3.60 m | 0.80 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 24.57 m/s | 0.3622 kPa |
| 3.20 m | 0.80 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 24.57 m/s | 0.3622 kPa |
| 2.80 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 21.95 m/s | 0.2891 kPa |
| 2.40 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 21.95 m/s | 0.2891 kPa |
| 2.00 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 21.95 m/s | 0.2891 kPa |
| 1.60 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 21.95 m/s | 0.2891 kPa |
| 1.20 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 21.95 m/s | 0.2891 kPa |
| 0.80 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 21.95 m/s | 0.2891 kPa |
| 0.40 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 21.95 m/s | 0.2891 kPa |
| 0.00 m | 0.80 | 0.8300 | 2  | 3.00 m | 15.85 m | 0.8934 | 1.0 | 21.95 m/s | 0.2891 kPa |

SOUTH WIND

| RL     | Md   | Mz,cat | ns | hs     | bs      | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|---------|--------|-----|-----------|------------|
| 4.00 m | 0.85 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 26.10 m/s | 0.4087 kPa |
| 3.60 m | 0.85 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 26.10 m/s | 0.4087 kPa |
| 3.20 m | 0.85 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 26.10 m/s | 0.4087 kPa |
| 2.80 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 25.12 m/s | 0.3786 kPa |
| 2.40 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 25.12 m/s | 0.3786 kPa |
| 2.00 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 25.12 m/s | 0.3786 kPa |
| 1.60 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 25.12 m/s | 0.3786 kPa |
| 1.20 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 25.12 m/s | 0.3786 kPa |
| 0.80 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 25.12 m/s | 0.3786 kPa |
| 0.40 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 25.12 m/s | 0.3786 kPa |
| 0.00 m | 0.85 | 0.8300 | 1  | 3.00 m | 12.65 m | 0.9623 | 1.0 | 25.12 m/s | 0.3786 kPa |

SOUTH WEST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs      | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|---------|--------|-----|-----------|------------|
| 4.00 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 29.17 m/s | 0.5105 kPa |
| 3.60 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 29.17 m/s | 0.5105 kPa |
| 3.20 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 29.17 m/s | 0.5105 kPa |
| 2.80 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 24.58 m/s | 0.3625 kPa |
| 2.40 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 24.58 m/s | 0.3625 kPa |
| 2.00 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 24.58 m/s | 0.3625 kPa |
| 1.60 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 24.58 m/s | 0.3625 kPa |
| 1.20 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 24.58 m/s | 0.3625 kPa |
| 0.80 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 24.58 m/s | 0.3625 kPa |
| 0.40 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 24.58 m/s | 0.3625 kPa |
| 0.00 m | 0.95 | 0.8300 | 4  | 3.00 m | 16.40 m | 0.8426 | 1.0 | 24.58 m/s | 0.3625 kPa |

WEST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs     | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|--------|--------|-----|-----------|------------|
| 4.00 m | 1.00 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 30.71 m/s | 0.5659 kPa |
| 3.60 m | 1.00 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 30.71 m/s | 0.5659 kPa |
| 3.20 m | 1.00 | 0.8300 | 0  | -      | -      | 1.0    | 1.0 | 30.71 m/s | 0.5659 kPa |
| 2.80 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 27.71 m/s | 0.4607 kPa |
| 2.40 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 27.71 m/s | 0.4607 kPa |
| 2.00 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 27.71 m/s | 0.4607 kPa |
| 1.60 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 27.71 m/s | 0.4607 kPa |
| 1.20 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 27.71 m/s | 0.4607 kPa |
| 0.80 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 27.71 m/s | 0.4607 kPa |
| 0.40 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 27.71 m/s | 0.4607 kPa |
| 0.00 m | 1.00 | 0.8300 | 4  | 3.00 m | 7.97 m | 0.9023 | 1.0 | 27.71 m/s | 0.4607 kPa |

NORTH WEST WIND

| RL     | Md   | Mz,cat | ns | hs     | bs      | Ms     | Mt  | Vsit,β    | qz         |
|--------|------|--------|----|--------|---------|--------|-----|-----------|------------|
| 4.00 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 29.17 m/s | 0.5105 kPa |
| 3.60 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 29.17 m/s | 0.5105 kPa |
| 3.20 m | 0.95 | 0.8300 | 0  | -      | -       | 1.0    | 1.0 | 29.17 m/s | 0.5105 kPa |
| 2.80 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 24.92 m/s | 0.3726 kPa |
| 2.40 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 24.92 m/s | 0.3726 kPa |
| 2.00 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 24.92 m/s | 0.3726 kPa |
| 1.60 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 24.92 m/s | 0.3726 kPa |
| 1.20 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 24.92 m/s | 0.3726 kPa |
| 0.80 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 24.92 m/s | 0.3726 kPa |
| 0.40 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 24.92 m/s | 0.3726 kPa |
| 0.00 m | 0.95 | 0.8300 | 4  | 3.00 m | 14.04 m | 0.8541 | 1.0 | 24.92 m/s | 0.3726 kPa |

----- EXTERNAL PRESSURES -----

LOAD CASE 01: Ultimate Wind

NORTH FACE

WALLS

| SURFACE  | DISTANCE FROM EDGE | Ka  | Cp,e    | pe        | pnet                  |
|----------|--------------------|-----|---------|-----------|-----------------------|
| Windward | All                | 1.0 | 0.7     | 0.53 kPa  | 0.53 kPa / 0.53 kPa   |
| Leeward  | All                | 1.0 | -0.3907 | -0.30 kPa | -0.30 kPa / -0.30 kPa |
| Side     | 0.00 m to 4.00 m   | 1.0 | -0.65   | -0.49 kPa | -0.49 kPa / -0.49 kPa |
|          | 4.00 m to 8.00 m   | 1.0 | -0.5    | -0.38 kPa | -0.38 kPa / -0.38 kPa |
|          | 8.00 m to 12.00 m  | 1.0 | -0.3    | -0.23 kPa | -0.23 kPa / -0.23 kPa |
|          | 12.00 m to 36.50 m | 1.0 | -0.2    | -0.15 kPa | -0.15 kPa / -0.15 kPa |

ROOF

| SURFACE    | DISTANCE FROM EDGE | Ka  | Cp,e              | pe                    | pnet                  |
|------------|--------------------|-----|-------------------|-----------------------|-----------------------|
| All Slopes | 0.00 m to 4.00 m   | 1.0 | -0.9000 / -0.4000 | -0.68 kPa / -0.30 kPa | -0.68 kPa / -0.30 kPa |
|            | 4.00 m to 8.00 m   | 1.0 | -0.5000 / 0.0000  | -0.38 kPa / 0.00 kPa  | -0.38 kPa / 0.00 kPa  |
|            | 8.00 m to 12.00 m  | 1.0 | -0.3000 / 0.1000  | -0.23 kPa / 0.08 kPa  | -0.23 kPa / 0.08 kPa  |
|            | 12.00 m to 36.50 m | 1.0 | -0.2000 / 0.2000  | -0.15 kPa / 0.15 kPa  | -0.15 kPa / 0.15 kPa  |

EAST FACE

WALLS

| SURFACE  | DISTANCE FROM EDGE | Ka  | Cp,e  | pe        | pnet                  |
|----------|--------------------|-----|-------|-----------|-----------------------|
| Windward | All                | 1.0 | 0.7   | 0.38 kPa  | 0.38 kPa / 0.38 kPa   |
| Leeward  | All                | 1.0 | -0.5  | -0.27 kPa | -0.27 kPa / -0.27 kPa |
| Side     | 0.00 m to 4.00 m   | 1.0 | -0.65 | -0.36 kPa | -0.36 kPa / -0.36 kPa |
|          | 4.00 m to 8.00 m   | 1.0 | -0.5  | -0.27 kPa | -0.27 kPa / -0.27 kPa |
|          | 8.00 m to 12.00 m  | 1.0 | -0.3  | -0.16 kPa | -0.16 kPa / -0.16 kPa |
|          | 12.00 m to 23.60 m | 1.0 | -0.2  | -0.11 kPa | -0.11 kPa / -0.11 kPa |

ROOF

| SURFACE    | DISTANCE FROM EDGE | Ka  | Cp,e              | pe                    | pnet                  |
|------------|--------------------|-----|-------------------|-----------------------|-----------------------|
| All Slopes | 0.00 m to 4.00 m   | 1.0 | -0.9000 / -0.4000 | -0.49 kPa / -0.22 kPa | -0.49 kPa / -0.22 kPa |
|            | 4.00 m to 8.00 m   | 1.0 | -0.5000 / 0.0000  | -0.27 kPa / 0.00 kPa  | -0.27 kPa / 0.00 kPa  |
|            | 8.00 m to 12.00 m  | 1.0 | -0.3000 / 0.1000  | -0.16 kPa / 0.05 kPa  | -0.16 kPa / 0.05 kPa  |
|            | 12.00 m to 23.60 m | 1.0 | -0.2000 / 0.2000  | -0.11 kPa / 0.11 kPa  | -0.11 kPa / 0.11 kPa  |

SOUTH FACE

WALLS

| SURFACE  | DISTANCE FROM EDGE | Ka  | Cp,e    | pe        | pnet                  |
|----------|--------------------|-----|---------|-----------|-----------------------|
| Windward | All                | 1.0 | 0.7     | 0.53 kPa  | 0.53 kPa / 0.53 kPa   |
| Leeward  | All                | 1.0 | -0.3907 | -0.30 kPa | -0.30 kPa / -0.30 kPa |
| Side     | 0.00 m to 4.00 m   | 1.0 | -0.65   | -0.49 kPa | -0.49 kPa / -0.49 kPa |
|          | 4.00 m to 8.00 m   | 1.0 | -0.5    | -0.38 kPa | -0.38 kPa / -0.38 kPa |
|          | 8.00 m to 12.00 m  | 1.0 | -0.3    | -0.23 kPa | -0.23 kPa / -0.23 kPa |
|          | 12.00 m to 36.50 m | 1.0 | -0.2    | -0.15 kPa | -0.15 kPa / -0.15 kPa |

ROOF

| SURFACE    | DISTANCE FROM EDGE | Ka  | Cp,e              | pe                    | pnet                  |
|------------|--------------------|-----|-------------------|-----------------------|-----------------------|
| All Slopes | 0.00 m to 4.00 m   | 1.0 | -0.9000 / -0.4000 | -0.68 kPa / -0.30 kPa | -0.68 kPa / -0.30 kPa |
|            | 4.00 m to 8.00 m   | 1.0 | -0.5000 / 0.0000  | -0.38 kPa / 0.00 kPa  | -0.38 kPa / 0.00 kPa  |
|            | 8.00 m to 12.00 m  | 1.0 | -0.3000 / 0.1000  | -0.23 kPa / 0.08 kPa  | -0.23 kPa / 0.08 kPa  |
|            | 12.00 m to 36.50 m | 1.0 | -0.2000 / 0.2000  | -0.15 kPa / 0.15 kPa  | -0.15 kPa / 0.15 kPa  |

WEST FACE

WALLS

| SURFACE  | DISTANCE FROM EDGE | Ka  | Cp,e  | pe        | pnet                  |
|----------|--------------------|-----|-------|-----------|-----------------------|
| Windward | All                | 1.0 | 0.7   | 0.59 kPa  | 0.59 kPa / 0.59 kPa   |
| Leeward  | All                | 1.0 | -0.5  | -0.42 kPa | -0.42 kPa / -0.42 kPa |
| Side     | 0.00 m to 4.00 m   | 1.0 | -0.65 | -0.54 kPa | -0.54 kPa / -0.54 kPa |
|          | 4.00 m to 8.00 m   | 1.0 | -0.5  | -0.42 kPa | -0.42 kPa / -0.42 kPa |
|          | 8.00 m to 12.00 m  | 1.0 | -0.3  | -0.25 kPa | -0.25 kPa / -0.25 kPa |
|          | 12.00 m to 23.60 m | 1.0 | -0.2  | -0.17 kPa | -0.17 kPa / -0.17 kPa |

ROOF

| SURFACE    | DISTANCE FROM EDGE | Ka  | Cp,e              | pe                    | pnet                  |
|------------|--------------------|-----|-------------------|-----------------------|-----------------------|
| All Slopes | 0.00 m to 4.00 m   | 1.0 | -0.9000 / -0.4000 | -0.75 kPa / -0.33 kPa | -0.75 kPa / -0.33 kPa |
|            | 4.00 m to 8.00 m   | 1.0 | -0.5000 / 0.0000  | -0.42 kPa / 0.00 kPa  | -0.42 kPa / 0.00 kPa  |
|            | 8.00 m to 12.00 m  | 1.0 | -0.3000 / 0.1000  | -0.25 kPa / 0.08 kPa  | -0.25 kPa / 0.08 kPa  |
|            | 12.00 m to 23.60 m | 1.0 | -0.2000 / 0.2000  | -0.17 kPa / 0.17 kPa  | -0.17 kPa / 0.17 kPa  |

LOAD CASE 02: Serviceability Wind

NORTH FACE

WALLS

| SURFACE | DISTANCE FROM EDGE | Ka | Cp,e | pe | pnet |
|---------|--------------------|----|------|----|------|
|---------|--------------------|----|------|----|------|

|                             |                    |     |                      |                   |                       |                       |           |           |
|-----------------------------|--------------------|-----|----------------------|-------------------|-----------------------|-----------------------|-----------|-----------|
| Windward                    | All                | 1.0 |                      | 0.7               | 0.36 kPa              | 0.36 kPa / 0.36 kPa   |           |           |
| Leeward                     | All                | 1.0 |                      | -0.3907           | -0.20 kPa             | -0.20 kPa / -0.20 kPa |           |           |
| Side                        | 0.00 m to 4.00 m   | 1.0 |                      | -0.65             | -0.33 kPa             | -0.33 kPa / -0.33 kPa |           |           |
|                             | 4.00 m to 8.00 m   | 1.0 |                      | -0.5              | -0.26 kPa             | -0.26 kPa / -0.26 kPa |           |           |
|                             | 8.00 m to 12.00 m  | 1.0 |                      | -0.3              | -0.15 kPa             | -0.15 kPa / -0.15 kPa |           |           |
|                             | 12.00 m to 36.50 m | 1.0 |                      | -0.2              | -0.10 kPa             | -0.10 kPa / -0.10 kPa |           |           |
| ROOF                        |                    |     |                      |                   |                       |                       |           |           |
| SURFACE                     | DISTANCE FROM EDGE | Ka  |                      | Cp,e              | pe                    | pnet                  |           |           |
| All Slopes                  | 0.00 m to 4.00 m   | 1.0 |                      | -0.9000 / -0.4000 | -0.46 kPa / -0.20 kPa | -0.46 kPa / -0.20 kPa |           |           |
|                             | 4.00 m to 8.00 m   | 1.0 |                      | -0.5000 / 0.0000  | -0.26 kPa / 0.00 kPa  | -0.26 kPa / 0.00 kPa  |           |           |
|                             | 8.00 m to 12.00 m  | 1.0 |                      | -0.3000 / 0.1000  | -0.15 kPa / 0.05 kPa  | -0.15 kPa / 0.05 kPa  |           |           |
|                             | 12.00 m to 36.50 m | 1.0 |                      | -0.2000 / 0.2000  | -0.10 kPa / 0.10 kPa  | -0.10 kPa / 0.10 kPa  |           |           |
| EAST FACE                   |                    |     |                      |                   |                       |                       |           |           |
| WALLS                       |                    |     |                      |                   |                       |                       |           |           |
| SURFACE                     | DISTANCE FROM EDGE | Ka  |                      | Cp,e              | pe                    | pnet                  |           |           |
| Windward                    | All                | 1.0 |                      | 0.7               | 0.26 kPa              | 0.26 kPa / 0.26 kPa   |           |           |
| Leeward                     | All                | 1.0 |                      | -0.5              | -0.19 kPa             | -0.19 kPa / -0.19 kPa |           |           |
| Side                        | 0.00 m to 4.00 m   | 1.0 |                      | -0.65             | -0.24 kPa             | -0.24 kPa / -0.24 kPa |           |           |
|                             | 4.00 m to 8.00 m   | 1.0 |                      | -0.5              | -0.19 kPa             | -0.19 kPa / -0.19 kPa |           |           |
|                             | 8.00 m to 12.00 m  | 1.0 |                      | -0.3              | -0.11 kPa             | -0.11 kPa / -0.11 kPa |           |           |
|                             | 12.00 m to 23.60 m | 1.0 |                      | -0.2              | -0.07 kPa             | -0.07 kPa / -0.07 kPa |           |           |
| ROOF                        |                    |     |                      |                   |                       |                       |           |           |
| SURFACE                     | DISTANCE FROM EDGE | Ka  |                      | Cp,e              | pe                    | pnet                  |           |           |
| All Slopes                  | 0.00 m to 4.00 m   | 1.0 |                      | -0.9000 / -0.4000 | -0.33 kPa / -0.15 kPa | -0.33 kPa / -0.15 kPa |           |           |
|                             | 4.00 m to 8.00 m   | 1.0 |                      | -0.5000 / 0.0000  | -0.19 kPa / 0.00 kPa  | -0.19 kPa / 0.00 kPa  |           |           |
|                             | 8.00 m to 12.00 m  | 1.0 |                      | -0.3000 / 0.1000  | -0.11 kPa / 0.04 kPa  | -0.11 kPa / 0.04 kPa  |           |           |
|                             | 12.00 m to 23.60 m | 1.0 |                      | -0.2000 / 0.2000  | -0.07 kPa / 0.07 kPa  | -0.07 kPa / 0.07 kPa  |           |           |
| SOUTH FACE                  |                    |     |                      |                   |                       |                       |           |           |
| WALLS                       |                    |     |                      |                   |                       |                       |           |           |
| SURFACE                     | DISTANCE FROM EDGE | Ka  |                      | Cp,e              | pe                    | pnet                  |           |           |
| Windward                    | All                | 1.0 |                      | 0.7               | 0.36 kPa              | 0.36 kPa / 0.36 kPa   |           |           |
| Leeward                     | All                | 1.0 |                      | -0.3907           | -0.20 kPa             | -0.20 kPa / -0.20 kPa |           |           |
| Side                        | 0.00 m to 4.00 m   | 1.0 |                      | -0.65             | -0.33 kPa             | -0.33 kPa / -0.33 kPa |           |           |
|                             | 4.00 m to 8.00 m   | 1.0 |                      | -0.5              | -0.26 kPa             | -0.26 kPa / -0.26 kPa |           |           |
|                             | 8.00 m to 12.00 m  | 1.0 |                      | -0.3              | -0.15 kPa             | -0.15 kPa / -0.15 kPa |           |           |
|                             | 12.00 m to 36.50 m | 1.0 |                      | -0.2              | -0.10 kPa             | -0.10 kPa / -0.10 kPa |           |           |
| ROOF                        |                    |     |                      |                   |                       |                       |           |           |
| SURFACE                     | DISTANCE FROM EDGE | Ka  |                      | Cp,e              | pe                    | pnet                  |           |           |
| All Slopes                  | 0.00 m to 4.00 m   | 1.0 |                      | -0.9000 / -0.4000 | -0.46 kPa / -0.20 kPa | -0.46 kPa / -0.20 kPa |           |           |
|                             | 4.00 m to 8.00 m   | 1.0 |                      | -0.5000 / 0.0000  | -0.26 kPa / 0.00 kPa  | -0.26 kPa / 0.00 kPa  |           |           |
|                             | 8.00 m to 12.00 m  | 1.0 |                      | -0.3000 / 0.1000  | -0.15 kPa / 0.05 kPa  | -0.15 kPa / 0.05 kPa  |           |           |
|                             | 12.00 m to 36.50 m | 1.0 |                      | -0.2000 / 0.2000  | -0.10 kPa / 0.10 kPa  | -0.10 kPa / 0.10 kPa  |           |           |
| WEST FACE                   |                    |     |                      |                   |                       |                       |           |           |
| WALLS                       |                    |     |                      |                   |                       |                       |           |           |
| SURFACE                     | DISTANCE FROM EDGE | Ka  |                      | Cp,e              | pe                    | pnet                  |           |           |
| Windward                    | All                | 1.0 |                      | 0.7               | 0.40 kPa              | 0.40 kPa / 0.40 kPa   |           |           |
| Leeward                     | All                | 1.0 |                      | -0.5              | -0.28 kPa             | -0.28 kPa / -0.28 kPa |           |           |
| Side                        | 0.00 m to 4.00 m   | 1.0 |                      | -0.65             | -0.37 kPa             | -0.37 kPa / -0.37 kPa |           |           |
|                             | 4.00 m to 8.00 m   | 1.0 |                      | -0.5              | -0.28 kPa             | -0.28 kPa / -0.28 kPa |           |           |
|                             | 8.00 m to 12.00 m  | 1.0 |                      | -0.3              | -0.17 kPa             | -0.17 kPa / -0.17 kPa |           |           |
|                             | 12.00 m to 23.60 m | 1.0 |                      | -0.2              | -0.11 kPa             | -0.11 kPa / -0.11 kPa |           |           |
| ROOF                        |                    |     |                      |                   |                       |                       |           |           |
| SURFACE                     | DISTANCE FROM EDGE | Ka  |                      | Cp,e              | pe                    | pnet                  |           |           |
| All Slopes                  | 0.00 m to 4.00 m   | 1.0 |                      | -0.9000 / -0.4000 | -0.51 kPa / -0.23 kPa | -0.51 kPa / -0.23 kPa |           |           |
|                             | 4.00 m to 8.00 m   | 1.0 |                      | -0.5000 / 0.0000  | -0.28 kPa / 0.00 kPa  | -0.28 kPa / 0.00 kPa  |           |           |
|                             | 8.00 m to 12.00 m  | 1.0 |                      | -0.3000 / 0.1000  | -0.17 kPa / 0.06 kPa  | -0.17 kPa / 0.06 kPa  |           |           |
|                             | 12.00 m to 23.60 m | 1.0 |                      | -0.2000 / 0.2000  | -0.11 kPa / 0.11 kPa  | -0.11 kPa / 0.11 kPa  |           |           |
| ----- LOCAL PRESSURES ----- |                    |     |                      |                   |                       |                       |           |           |
| LOAD CASE 01: Ultimate Wind |                    |     |                      |                   |                       |                       |           |           |
| NORTH FACE                  |                    |     |                      |                   |                       |                       |           |           |
| WALLS                       |                    |     |                      |                   |                       |                       |           |           |
| SURFACE                     | DISTANCE FROM EDGE | REF | AREA                 |                   | K1                    | Cfig,e                | pe        | pnet      |
| Windward                    | All                | WA1 | 4.00 m <sup>2</sup>  |                   | 1.5                   | 1.0500                | 0.79 kPa  | 0.79 kPa  |
| Side                        | 0.00 m to 4.00 m   | SA1 | 16.00 m <sup>2</sup> |                   | 1.5                   | -0.9750               | -0.74 kPa | -0.74 kPa |
|                             | 0.00 m to 2.00 m   | SA2 | 4.00 m <sup>2</sup>  |                   | 2.0                   | -1.3000               | -0.98 kPa | -0.98 kPa |
| ROOF                        |                    |     |                      |                   |                       |                       |           |           |
| SURFACE                     | DISTANCE FROM EDGE | REF | AREA                 | Kr                | K1                    | Cfig,e                | pe        | pnet      |

|                                   |                    |     |                      |        |     |         |           |           |
|-----------------------------------|--------------------|-----|----------------------|--------|-----|---------|-----------|-----------|
| Upwind Edges                      | 0.00 m to 4.00 m   | RA1 | 16.00 m <sup>2</sup> | 1.0000 | 1.5 | -1.3500 | -1.02 kPa | -1.02 kPa |
|                                   | 0.00 m to 2.00 m   | RA2 | 4.00 m <sup>2</sup>  | 1.0000 | 2.0 | -1.8000 | -1.36 kPa | -1.36 kPa |
| Upwind Corners                    | 0.00 m to 4.00 m   | RC1 | 4.00 m <sup>2</sup>  | 1.0000 | 3.0 | -2.7000 | -2.04 kPa | -2.04 kPa |
| EAST FACE                         |                    |     |                      |        |     |         |           |           |
| WALLS                             |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 |        | K1  | Cfig,e  | pe        | pnet      |
| Windward                          | All                | WA1 | 4.00 m <sup>2</sup>  |        | 1.5 | 1.0500  | 0.57 kPa  | 0.57 kPa  |
| Side                              | 0.00 m to 4.00 m   | SA1 | 16.00 m <sup>2</sup> |        | 1.5 | -0.9750 | -0.53 kPa | -0.53 kPa |
|                                   | 0.00 m to 2.00 m   | SA2 | 4.00 m <sup>2</sup>  |        | 2.0 | -1.3000 | -0.71 kPa | -0.71 kPa |
| ROOF                              |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 | Kr     | K1  | Cfig,e  | pe        | pnet      |
| Upwind Edges                      | 0.00 m to 4.00 m   | RA1 | 16.00 m <sup>2</sup> | 1.0000 | 1.5 | -1.3500 | -0.74 kPa | -0.74 kPa |
|                                   | 0.00 m to 2.00 m   | RA2 | 4.00 m <sup>2</sup>  | 1.0000 | 2.0 | -1.8000 | -0.99 kPa | -0.99 kPa |
| Upwind Corners                    | 0.00 m to 4.00 m   | RC1 | 4.00 m <sup>2</sup>  | 1.0000 | 3.0 | -2.7000 | -1.48 kPa | -1.48 kPa |
| SOUTH FACE                        |                    |     |                      |        |     |         |           |           |
| WALLS                             |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 |        | K1  | Cfig,e  | pe        | pnet      |
| Windward                          | All                | WA1 | 4.00 m <sup>2</sup>  |        | 1.5 | 1.0500  | 0.79 kPa  | 0.79 kPa  |
| Side                              | 0.00 m to 4.00 m   | SA1 | 16.00 m <sup>2</sup> |        | 1.5 | -0.9750 | -0.74 kPa | -0.74 kPa |
|                                   | 0.00 m to 2.00 m   | SA2 | 4.00 m <sup>2</sup>  |        | 2.0 | -1.3000 | -0.98 kPa | -0.98 kPa |
| ROOF                              |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 | Kr     | K1  | Cfig,e  | pe        | pnet      |
| Upwind Edges                      | 0.00 m to 4.00 m   | RA1 | 16.00 m <sup>2</sup> | 1.0000 | 1.5 | -1.3500 | -1.02 kPa | -1.02 kPa |
|                                   | 0.00 m to 2.00 m   | RA2 | 4.00 m <sup>2</sup>  | 1.0000 | 2.0 | -1.8000 | -1.36 kPa | -1.36 kPa |
| Upwind Corners                    | 0.00 m to 4.00 m   | RC1 | 4.00 m <sup>2</sup>  | 1.0000 | 3.0 | -2.7000 | -2.04 kPa | -2.04 kPa |
| WEST FACE                         |                    |     |                      |        |     |         |           |           |
| WALLS                             |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 |        | K1  | Cfig,e  | pe        | pnet      |
| Windward                          | All                | WA1 | 4.00 m <sup>2</sup>  |        | 1.5 | 1.0500  | 0.88 kPa  | 0.88 kPa  |
| Side                              | 0.00 m to 4.00 m   | SA1 | 16.00 m <sup>2</sup> |        | 1.5 | -0.9750 | -0.82 kPa | -0.82 kPa |
|                                   | 0.00 m to 2.00 m   | SA2 | 4.00 m <sup>2</sup>  |        | 2.0 | -1.3000 | -1.09 kPa | -1.09 kPa |
| ROOF                              |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 | Kr     | K1  | Cfig,e  | pe        | pnet      |
| Upwind Edges                      | 0.00 m to 4.00 m   | RA1 | 16.00 m <sup>2</sup> | 1.0000 | 1.5 | -1.3500 | -1.13 kPa | -1.13 kPa |
|                                   | 0.00 m to 2.00 m   | RA2 | 4.00 m <sup>2</sup>  | 1.0000 | 2.0 | -1.8000 | -1.51 kPa | -1.51 kPa |
| Upwind Corners                    | 0.00 m to 4.00 m   | RC1 | 4.00 m <sup>2</sup>  | 1.0000 | 3.0 | -2.7000 | -2.26 kPa | -2.26 kPa |
| LOAD CASE 02: Serviceability Wind |                    |     |                      |        |     |         |           |           |
| NORTH FACE                        |                    |     |                      |        |     |         |           |           |
| WALLS                             |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 |        | K1  | Cfig,e  | pe        | pnet      |
| Windward                          | All                | WA1 | 4.00 m <sup>2</sup>  |        | 1.5 | 1.0500  | 0.54 kPa  | 0.54 kPa  |
| Side                              | 0.00 m to 4.00 m   | SA1 | 16.00 m <sup>2</sup> |        | 1.5 | -0.9750 | -0.50 kPa | -0.50 kPa |
|                                   | 0.00 m to 2.00 m   | SA2 | 4.00 m <sup>2</sup>  |        | 2.0 | -1.3000 | -0.66 kPa | -0.66 kPa |
| ROOF                              |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 | Kr     | K1  | Cfig,e  | pe        | pnet      |
| Upwind Edges                      | 0.00 m to 4.00 m   | RA1 | 16.00 m <sup>2</sup> | 1.0000 | 1.5 | -1.3500 | -0.69 kPa | -0.69 kPa |
|                                   | 0.00 m to 2.00 m   | RA2 | 4.00 m <sup>2</sup>  | 1.0000 | 2.0 | -1.8000 | -0.92 kPa | -0.92 kPa |
| Upwind Corners                    | 0.00 m to 4.00 m   | RC1 | 4.00 m <sup>2</sup>  | 1.0000 | 3.0 | -2.7000 | -1.38 kPa | -1.38 kPa |
| EAST FACE                         |                    |     |                      |        |     |         |           |           |
| WALLS                             |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 |        | K1  | Cfig,e  | pe        | pnet      |
| Windward                          | All                | WA1 | 4.00 m <sup>2</sup>  |        | 1.5 | 1.0500  | 0.39 kPa  | 0.39 kPa  |
| Side                              | 0.00 m to 4.00 m   | SA1 | 16.00 m <sup>2</sup> |        | 1.5 | -0.9750 | -0.36 kPa | -0.36 kPa |
|                                   | 0.00 m to 2.00 m   | SA2 | 4.00 m <sup>2</sup>  |        | 2.0 | -1.3000 | -0.48 kPa | -0.48 kPa |
| ROOF                              |                    |     |                      |        |     |         |           |           |
| SURFACE                           | DISTANCE FROM EDGE | REF | AREA                 | Kr     | K1  | Cfig,e  | pe        | pnet      |
| Upwind Edges                      | 0.00 m to 4.00 m   | RA1 | 16.00 m <sup>2</sup> | 1.0000 | 1.5 | -1.3500 | -0.50 kPa | -0.50 kPa |
|                                   | 0.00 m to 2.00 m   | RA2 | 4.00 m <sup>2</sup>  | 1.0000 | 2.0 | -1.8000 | -0.67 kPa | -0.67 kPa |
| Upwind Corners                    | 0.00 m to 4.00 m   | RC1 | 4.00 m <sup>2</sup>  | 1.0000 | 3.0 | -2.7000 | -1.00 kPa | -1.00 kPa |
| SOUTH FACE                        |                    |     |                      |        |     |         |           |           |

| WALLS          |                                      |     |                      |        |     |         |           |           |  |
|----------------|--------------------------------------|-----|----------------------|--------|-----|---------|-----------|-----------|--|
| SURFACE        | DISTANCE FROM EDGE                   | REF | AREA                 |        | K1  | Cfig,e  | pe        | pnet      |  |
| Windward       | All                                  | WA1 | 4.00 m <sup>2</sup>  |        | 1.5 | 1.0500  | 0.54 kPa  | 0.54 kPa  |  |
| Side           | 0.00 m to 4.00 m<br>0.00 m to 2.00 m | SA1 | 16.00 m <sup>2</sup> |        | 1.5 | -0.9750 | -0.50 kPa | -0.50 kPa |  |
|                |                                      | SA2 | 4.00 m <sup>2</sup>  |        | 2.0 | -1.3000 | -0.66 kPa | -0.66 kPa |  |
| ROOF           |                                      |     |                      |        |     |         |           |           |  |
| SURFACE        | DISTANCE FROM EDGE                   | REF | AREA                 | Kr     | K1  | Cfig,e  | pe        | pnet      |  |
| Upwind Edges   | 0.00 m to 4.00 m<br>0.00 m to 2.00 m | RA1 | 16.00 m <sup>2</sup> | 1.0000 | 1.5 | -1.3500 | -0.69 kPa | -0.69 kPa |  |
|                |                                      | RA2 | 4.00 m <sup>2</sup>  | 1.0000 | 2.0 | -1.8000 | -0.92 kPa | -0.92 kPa |  |
| Upwind Corners | 0.00 m to 4.00 m                     | RC1 | 4.00 m <sup>2</sup>  | 1.0000 | 3.0 | -2.7000 | -1.38 kPa | -1.38 kPa |  |
| WEST FACE      |                                      |     |                      |        |     |         |           |           |  |
| WALLS          |                                      |     |                      |        |     |         |           |           |  |
| SURFACE        | DISTANCE FROM EDGE                   | REF | AREA                 |        | K1  | Cfig,e  | pe        | pnet      |  |
| Windward       | All                                  | WA1 | 4.00 m <sup>2</sup>  |        | 1.5 | 1.0500  | 0.59 kPa  | 0.59 kPa  |  |
| Side           | 0.00 m to 4.00 m<br>0.00 m to 2.00 m | SA1 | 16.00 m <sup>2</sup> |        | 1.5 | -0.9750 | -0.55 kPa | -0.55 kPa |  |
|                |                                      | SA2 | 4.00 m <sup>2</sup>  |        | 2.0 | -1.3000 | -0.74 kPa | -0.74 kPa |  |
| ROOF           |                                      |     |                      |        |     |         |           |           |  |
| SURFACE        | DISTANCE FROM EDGE                   | REF | AREA                 | Kr     | K1  | Cfig,e  | pe        | pnet      |  |
| Upwind Edges   | 0.00 m to 4.00 m<br>0.00 m to 2.00 m | RA1 | 16.00 m <sup>2</sup> | 1.0000 | 1.5 | -1.3500 | -0.76 kPa | -0.76 kPa |  |
|                |                                      | RA2 | 4.00 m <sup>2</sup>  | 1.0000 | 2.0 | -1.8000 | -1.02 kPa | -1.02 kPa |  |
| Upwind Corners | 0.00 m to 4.00 m                     | RC1 | 4.00 m <sup>2</sup>  | 1.0000 | 3.0 | -2.7000 | -1.53 kPa | -1.53 kPa |  |

----- REFERENCES -----

[1] American Association of State Highway and Transportation Officials (AASHTO) 2019, 'LRFD LTS-1 LRFD Specifications for Structural Supports for Highway Signs, Luminaries, and Traffic Signals'.

[2] American Society of Civil Engineers (ASCE) 2014, 'ASCE/SEI 7-10 Minimum Design Loads and Associated Criteria for Buildings and Other Structures'.

[3] American Society of Civil Engineers (ASCE) 2017, 'ASCE/SEI 7-16 Minimum Design Loads and Associated Criteria for Buildings and Other Structures'.

[4] Australasian Wind Engineering Society (AWES) 2012, 'Wind Loadings Handbook for Australia and New Zealand Background to AS/NZS 1170.2 Wind Actions'.

[5] Bureau of Indian Standards 2015, 'IS 875 (Part 3): 2015 Design Loads (Other than Earthquake) for Buildings and Structures - Code of Practice Part 3 Wind Loads (Third Revision)'.

[6] Standards Australia/Standards New Zealand 2007, 'AS/NZS 1170.3:2003 Structural design actions Part 3: Snow and ice actions'.

[7] Standards Australia/Standards New Zealand 2009, 'AS/NZS 1170.1:2002 Structural design actions Part 1: Permanent, imposed and other actions'.

[8] Standards Australia/Standards New Zealand 2011, 'AS/NZS 1170.0:2002 Structural design actions Part 0: General principles'.

[9] Standards Australia/Standards New Zealand 2017, 'AS/NZS 1170.2:2011 Structural design actions Part 2: Wind actions'.

[10] Telecommunications Industry Association 2014, 'TIA-222-G-2 Structural Standard for Antenna Supporting Structures and Antennas'.

[11] Telecommunications Industry Association 2019, 'TIA-222-H-1 Structural Standard for Antenna Supporting Structures and Antennas and Small Wind Turbine Support Structures'.