

ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the Electricity Act 1996



Certificate Number: **E1229085**

Owner/Client name	Onkaparinga Council		
Installation Address	100 Taylors Road, ABERFOYLE PARK, SA 5159		
Premises Type	Commercial		
Date of Electrical Work	Started: 20/09/2021	Finished: 20/09/2021	Submitted: 20/09/2021
Network Operator	SAPN		

SECTION A - JOB DETAILS

Job Category	Job Type	Work Performed
Alter/Addition	Other	Electrical Work Details: Install panel isolator Install 63amp three phase meter isolator and 63amp single phase meter isolator All other wiring existing

SECTION B - WARNING : Owners & operators of electrical installations must take reasonable steps to ensure that the electrical installation is safe. Maximum penalty \$250,000. Listed below are any items considered to be unsafe or requiring remedy.

Risk Assessment	Recommend
Risk Assessment Details	Recommend switchboard upgrade

REGISTERED ELECTRICAL WORKER: I certify the work detailed in this eCoC complies with and has been inspected and tested by me as required by the *Electricity Act 1996*.

Name	Torsten Rutter
Licence Number	PGE174524
Date Certified	20/09/2021

CONTRACTOR/AUTHORISED PERSON: I certify that I am the contractor/duly authorised agent of the contractor and have or had a supervisory role in relation to the worker above and I am satisfied that the standards and requirements of the *Electricity Act 1996* have been complied with.

Also where applicable, I am satisfied that the auxiliary gas fitting and/or water plumbing work detailed above meets the requirements of the *Gas Act 1997* and Regulations and/or *Water Industry Act 2012* including Regulations and Standards.

Name	Torsten Rutter		
Business Name	Sparkwire Electrical Pty Ltd		
Licence Number	BLD292655		
Phone/Mobile	0410696922	Email	sparkwire@hotmail.com
Address	200B GRANGE ROAD, FLINDERS PARK, SA 5025		
Date Certified	20/09/2021		

The Technical Regulator does not endorse the contents of this electronic Certificate of Compliance (eCoC). The Technical Regulator does not accept responsibility for the truth or accuracy of the contents of this eCoC and will not be held liable for any loss or damage suffered in consequence of reliance upon the contents of this eCoC.

ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the *Electricity Act 1996*

Certificate Number: **E1229085**

Information for Owners and Operators of Electrical Installations

(From the *Electricity Act 1996*)

Section 60 of the *Electricity Act 1996*

60—Responsibility of owner or operator of infrastructure or installation

(1b) A person who owns or operates an electrical installation must take reasonable steps to ensure that—

- (a) the installation complies with, and is operated in accordance with, technical and safety requirements imposed under the regulations; and
- (b) the installation is safe and safely operated.

Maximum penalty:

- (a) if the offender is a body corporate—a penalty of \$50 000;
- (b) in any other case—a penalty of \$10 000.

Expiation fee: \$315.

(2) For the purpose of ensuring under this section that an electrical installation complies with the technical and safety requirements and is safe, a person may, subject to the regulations, rely on a certificate of compliance issued under this Part in relation to the installation.

Section 61 of the *Electricity Act 1996*

61—Electrical installation work

(1) A person to whom this subsection applies who carries out work on an electrical installation or proposed electrical installation must ensure that—

- (a) the work is carried out as required under the regulations; and
- (b) examinations and tests are carried out as required under the regulations; and
- (c) the requirements of the regulations as to notification and certificates of compliance are complied with.

Maximum penalty:

- (a) if the offender is a body corporate—a penalty of \$50 000;
- (b) in any other case—a penalty of \$10 000.

Expiation fee: \$315.