

ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the Electricity Act 1996

Certificate Number: **E1287685**

Owner/Client name	Westside Energy		
Installation Address	148 Port Road, ALDINGA, SA 5173		
Premises Type	Other		
Date of Electrical Work	Started: 05/07/2021	Finished: 16/11/2021	Submitted: 16/11/2021
Network Operator	SAPN		

SECTION A - JOB DETAILS

Job Category	Job Type	Work Performed
New Install	Inverter/Battery/ Solar/Generator	Grid Connected Relevant Agent: SA Power Networks - WattWatchers Solar Solar Manufacturer: LONGi Green Energy Technology Co Ltd Module Model: LR4-72HPH-450M Solar Number of Modules: 318 Solar Total Capacity: 143.10 (kW) Inverter Inverter Manufacturer: Sungrow Power Supply Co Ltd Inverter Model: SG50CX Inverter Serial Number: A2005294144;A2005294170;A2005294209;A2005294162 Inverter Grid Code Settings: TS130 Electrical Work Details: Installed PV System

SECTION B - WARNING : Owners & operators of electrical installations must take reasonable steps to ensure that the electrical installation is safe. Maximum penalty \$250,000. Listed below are any items considered to be unsafe or requiring remedy.

Risk Assessment	None Observed
-----------------	---------------

REGISTERED ELECTRICAL WORKER: I certify the work detailed in this eCoC complies with and has been inspected and tested by me as required by the *Electricity Act 1996*.

Name	Corey Evans
Licence Number	PGE291719
Date Certified	16/11/2021

ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the Electricity Act 1996



Certificate Number: **E1287685**

CONTRACTOR/AUTHORISED PERSON: I certify that I am the contractor/duly authorised agent of the contractor and have or had a supervisory role in relation to the worker above and I am satisfied that the standards and requirements of the *Electricity Act 1996* have been complied with.
Also where applicable, I am satisfied that the auxiliary gas fitting and/or water plumbing work detailed above meets the requirements of the *Gas Act 1997* and Regulations and/or *Water Industry Act 2012* including Regulations and Standards.

Name	Corey Evans		
Business Name	Evans Electrical Contracting		
Licence Number	PGE289810		
Phone/Mobile	0433972308	Email	corey@evanselectrical.com.au
Address	59 QUEEN STREET, ALBERTON, SA 5014		
Date Certified	16/11/2021		

The Technical Regulator does not endorse the contents of this electronic Certificate of Compliance (eCoC). The Technical Regulator does not accept responsibility for the truth or accuracy of the contents of this eCoC and will not be held liable for any loss or damage suffered in consequence of reliance upon the contents of this eCoC.

ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the *Electricity Act 1996*

Certificate Number: **E1287685**

Information for Owners and Operators of Electrical Installations

(From the *Electricity Act 1996*)

Section 60 of the *Electricity Act 1996*

60—Responsibility of owner or operator of infrastructure or installation

(1b) A person who owns or operates an electrical installation must take reasonable steps to ensure that—

- (a) the installation complies with, and is operated in accordance with, technical and safety requirements imposed under the regulations; and
- (b) the installation is safe and safely operated.

Maximum penalty:

- (a) if the offender is a body corporate—a penalty of \$50 000;
- (b) in any other case—a penalty of \$10 000.

Expiation fee: \$315.

(2) For the purpose of ensuring under this section that an electrical installation complies with the technical and safety requirements and is safe, a person may, subject to the regulations, rely on a certificate of compliance issued under this Part in relation to the installation.

Section 61 of the *Electricity Act 1996*

61—Electrical installation work

(1) A person to whom this subsection applies who carries out work on an electrical installation or proposed electrical installation must ensure that—

- (a) the work is carried out as required under the regulations; and
- (b) examinations and tests are carried out as required under the regulations; and
- (c) the requirements of the regulations as to notification and certificates of compliance are complied with.

Maximum penalty:

- (a) if the offender is a body corporate—a penalty of \$50 000;
- (b) in any other case—a penalty of \$10 000.

Expiation fee: \$315.